

SUMP PIT MAX 1800 (6'-0") DEEP

TC-SOG-31

FOR CAST-IN L'S & COVER, SEE MECH & ARCH DWGS
OR **TS-MISC-42**

SLAB ON GRADE REINFORCEMENT
IF CALLED FOR ON PLAN

ADD 10@300 (12")B
x 1500 (5'-0") LG

ROUGHEN JOINT TO
5mm (3/16") AMPLITUDE

DOWELS TO MATCH
WALL VERTICALS

STANDARD HOOK (TYP)

FOR WATERPROOFING REQUIREMENTS REFER
TO ARCH AND MECHANICAL DRAWINGS

1-10 CONT
10@200 (8") EACH WAY
IN CENTRE OF WALLS

1400 (4'-6") MAX

150 (6")

150 (6")

10@200 (8") BEW

CONTINUOUS PVC
WATERSTOP, REFER TO
SPECIFICATIONS

CLASS 'B'
LAP

SEE PLAN
1800 (6'-0") MAX

200
(8")

NOTES:

1. THIS DETAIL MAY BE USED FOR DEEPER PITS WHERE SPECIFICALLY NOTED ON PLANS.
2. SEE **TC-SOG-41** FOR SOG DIAGONAL BARS ADDED AT PIT CORNERS.