

SEISMIC REINFORCEMENT FOR NON-LOAD BEARING MASONRY WALLS WITH SEISMIC HAZARD INDEX $0.35 \leq I_E$ F_a $S_a(0.2) < 0.75$

TM-WALL-01

WALL THICKNESS	VERTICAL REINFORCEMENT	HORIZONTAL JOINT REINFORCEMENT
140 (6")	1-10@800 (2'-8")	2-3.66 @ 400 (16")
190 OR 240 (8" OR 10")	1-10@1200 (4'-0")	2-3.66 @ 400 (16")
290 (12")	1-10@1000 (3'-4")	2-3.66 @ 400 (16")

NOTES:

1. UNLESS NOTED OTHERWISE, PROVIDE THE ABOVE REINFORCEMENT FOR ALL MASONRY WALLS.
2. SEE MASONRY NOTES FOR DOWELLING, SPLICING AND OTHER REINFORCING AND GROUTING REQUIREMENTS.