

FEBRUARY 12, 2025

CONSULTANT:

ARCHITECT:

SEAL:

CITY SEAL:

DISCLAIMER: THIS DRAWING AND DESIGN IS COPYRIGHT PROTECTED WHICH SHALL NOT BE USED, REPRODUCED OR REVISED WITHOUT WRITTEN PERMISSION BY PETSMART. THE CONTRACTOR SHALL CHECK AND VERIFY ALL DIMENSIONS AND UTILITY LOCATIONS AND REPORT ALL ERRORS AND OMISSIONS PRIOR TO COMMENCING WORK.


THIS DRAWING IS NOT TO BE SCALED.

ISSUED FOR:

PROJECT NO:	DATE:
CA0045686.0146	02.12.25
ORIGINAL SCALE:	IF THIS BAR IS NO LONG, ADJUST YOUR PLOTTING SCALE
AS NOTED	
DESIGNED BY:	
DRAWN BY:	
CHECKED BY:	
PAGE #:	OF:

36	53	
----	----	--

SHEET NUMBER: 334



- A. EXPOSED SUPPLY/RETURN DUCTWORK SHALL BE INTERNALLY LINED (NO DUCT WRAP INSULATION FOR EXPOSED DUCTWORK).
- B. ALL CONCEALED SUPPLY/RETURN DUCTWORK (ABOVE CEILING) IS TO BE THERMALLY INSULATED, INCLUDING FLEXIBLE SPIRAL DUCTING.
- C. ALL VERTICAL SUPPLY AIR DUCTWORK DROPS FROM THE ROOF TOP UNITS SHALL HAVE SMOOTH RADIUS BEND TRANSITION TO THE HORIZONTAL DISTRIBUTION.
- D. ALL VOLUME DAMPERS FOR AIR DEVICES SHALL BE INSTALLED TO BE ACCESSIBLE FOR BALANCING/LOCATE WITHIN 24" OF CEILING.
- E. VOLUME DAMPERS SHALL HAVE 1" STAND-OFFS FOR INSULATION THICKNESS.
- F. ALL DAMPERS MUST HAVE FLUORESCENT TAPE FLAGGING FOR LOCATING.

1 DIFFUSERS TO BE AIMED ON A 45° DOWNWARDS ANGLE.