



HVAC SYMBOLS LEGEND		
ITEM	ABBR.	DESCRIPTION
	-	RECTANGULAR DUCT
	-	ROUND DUCT
	-	45° TAP – USE AT BRANCH DUCTS ONLY
	-	CURVED (LONG SWEEP) DUCT ELBOW – MINIMUM RADIUS R=1.5 x WIDTH
	-	90° RECTANGULAR DUCT ELBOW WITH SINGLE RADIUS TURNING VANES
	FD	FIRE DAMPER – COMBO FIRE / SMOKE DAMPER
	BD	BALANCING DAMPER (USE O.B.D. UNLESS NOTED OTHERWISE)
	-	SPIN-IN DUCT TAKE-OFF W/ DAMPER
	BDD	BACKDRAFT DAMPER
	SA	SUPPLY AIR DUCT
	EXH	EXHAUST AIR DUCT
	RA	RETURN AIR DUCT
	TSTAT	THERMOSTAT
	RTS	REMOTE TEMPERATURE SENSOR
	HS	REMOTE HUMIDITY/TEMPERATURE SENSOR
	ES	NEXREV EMS TEMPERATURE SENSOR
	-	OPEN-ENDED DUCT
	-	1-WAY THROW DIFFUSER
	-	2-WAY THROW DIFFUSER
	-	2-WAY THROW DIFFUSER
	-	3-WAY THROW DIFFUSER
	-	4-WAY THROW DIFFUSER
	-	RETURN DIFFUSER
	-	EXHAUST DIFFUSER
	-	DIFFUSER IDENTIFICATION A=STYLE, B=AIRFLOW cfm, C=SIZE inches
	-	MECHANICAL/PLUMBING EQUIPMENT DESIGNATION MARK (DESIGNATION FOR SPECIFICATION OR MARK FOR SCHEDULE ON DRAWING)
	-	SPOT ELEVATION, MEASURED FROM BOTTOM OF DUCT



DISCLAIMER: THIS DRAWING AND DESIGN IS COPYRIGHT PROTECTED WHICH SHALL NOT BE USED, REPRODUCED OR REVISED WITHOUT WRITTEN PERMISSION BY PETSMART. THE CONTRACTOR SHALL CHECK AND VERIFY ALL DIMENSIONS AND UTILITY LOCATIONS AND REPORT ALL ERRORS AND OMISSIONS PRIOR TO COMMENCING WORK.

ISSUED FOR

PROJECT NO:	DATE:
CA0073426.0987	05.08.26
ORIGINAL SCALE:	IF THIS BAR IS NOT 1" LONG, ADJUST YOUR PLOTTING SCALE.
AS NOTED	
DESIGNED BY:	
DRAWN BY:	
CHECKED BY:	 1"
PAGE #:	
39	OF: 54

SHEET NUMBER:

M2.0