

SECTION 07720: ROOF ACCESSORIES

PART I – GENERAL

WORK SPECIFIED HEREIN

All labor, materials, equipment and services necessary to furnish and install all roof hatches as indicated or specified.

SUBMITTALS

Unless otherwise noted, the contractor shall prepare all shop drawings, product literature, etc. only as required to properly coordinate and construct the project.

Review of submittals by the Professional of Record is limited to specific shop drawings as called for in this Project Manual.

Shop drawings for review by the Professional of Record are not required for this section.

SUBSTITUTIONS

In accordance with Section 01600.

PART II – PRODUCTS

MATERIALS

This specification is based on roof hatches as manufactured by those listed within the Material and Product Schedule shown on the Drawings.

Covers shall be galvanized steel, prime painted, 14 gauge with 3" beaded flange neatly welded. Insulation shall be glass fiber, 1" in thickness, fully covered and protected by a galvanized steel, prime painted, 22 gauge metal liner. Curb shall be 12" high of galvanized steel, prime painted, 14 gauge, formed with a 3-1/2" flange with holes provided for securing to roof deck. Equip curb with an integral metal cap flashing of the same gauge and material as the curb, full welded at the corners for absolute weather tightness. Insulation on exterior of the curb shall be 1" thick rigid fiberboard.

PART III – EXECUTION

INSTALLATION

Install roof hatches at location indicated, fastening securely to deck through curb flange.

END OF SECTION

This Page Intentionally Left Blank.